CODES AND TECHNICAL STANDARDS COMMITTEE FORMAL INTERPRETATION

REFERENCE NUMBER: 82.224.161.97.08

REFERENCE DOCUMENT: Life Safety Code 1994 Existing

13-3.2.1, 13-3.2.2, and A-13-3.2.2

LOCATION: PHOENIX AREA INDIAN HEALTH SERVICE

PHOENIX, AZ

QUESTION: Phoenix Area Division of Facility Management

requests authority to build laboratories which do not meet NFPA-99, Chapter 10 and

NFPA-45.

ANSWER: Authority not recommended

COMMENTS: Each Laboratory setup and requirements could

be unique using various quantities and types of chemicals. The code shall be interpreted

individually by the authority having

jurisdiction.

Signatures:

√A Agree [] Disagree	Mun Dourn_	5-7-97
[] Dibagice	Steven L Bourn, R.A. (ES-Dallas)	(Date)
Agree	MarnoBuche	5-7-97
_	Mark Burke, E.I.T. (ES-Dallas)	(Date)
[∤ Agree [] Disagree	(- any W. Sue for	5/12/97
[] 21209100	Gerry Shaffer, R.A. (ES-Dallas)	(Date)
M Agree	to too	5-7-97
[] Disagree	Yusuf Vora, P.E. (ES-Dallas)	(Date)
[] Agree	Howard R. Minter	5/1/97
[] Disagree	Howard Minter, P.E. (ES-Dallas)	(Date)
Agree [] Disagree	Devent ans	6.12.97
[] Disagree	(ES-Seatle)	(Date)